

EC Type-Examination Certificate



according to Directive 2009/142/EC Article 8, section 1. (a)
relating to appliances burning gaseous fuels

Certificate No.: MB 69246184 0001 **PIN:** 1008 CP 2745
Test Report No.: 28218091 002
Certificate Holder: Pakole Trade Kft.
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.
Manufacturer: Pakole Trade Kft.
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.
Product: Group: Heating and air conditioning appliances (3300)
Gas-fired overhead radiant tube heaters (3311)
Identification: Model: ZENIT..., OMEGA..., Infragaz IGT...
See details in Annex I.
Tested according to: EN 416-1:2009
Countries of destination: AT, BE, BY, CY, CZ, DK, GB, EE, FI, FR, GR, NL, IE, PL,
LV, LT, LU, HU, DE, NO, IT, PT, RO, ES, CH, SE, SK, SI,
TR, UA, RU, BA, BG, MD, RS, HR

This type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Directive. The Certificate Holder is entitled to use this certificate in connection with the EC Declaration of Conformity in accordance with the Directive. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

Date of issue:
Budapest, 29.01.2014



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
Notified under No. 1008 to the EC Commission

CE The CE marking may be used if all relevant and effective EC directives are complied with. **CE**

Annex I to certificate No. MB 69246184 0001

Page 1/1

PIN: 1008 CP 2745

Destination countries	Appliance categories	Nominal gas supply pressure (mbar)		Models of appliances ZENIT... OMEGA... Infragaz IGT...	Nominal heat input (kW)
		2 nd family	3 rd family		
AT	II _{2H3B/P}	20	50	... 12	12
BE	II _{2E+3+}	20/25	30/37	... 14	14
BG	II _{2H3B/P}	20	30	... 16	16
BY	II _{2H3B/P}	20	30, 50	... 18	18
CY	II _{2H3+}	20	30/37	... 20	20
CZ	II _{2H3P}	20	37	... 22	22
DK	II _{2H3B/P}	20	30	... 24	24
GB	II _{2H3+} , II _{2H3P}	20	37/50, 37, 50	... 26	26
EE	II _{2H3B/P}	20	30	... 28	28
FI	II _{2H3B/P}	20	30	... 30	30
FR	II _{2E+3+}	20/25	30/37	... 32	32
GR	II _{2H3+} , II _{2H3P}	20	30/37, 37	... 34	34
NL	I _{3B/P} , I _{3P}		30, 50	... 36	36
IE	I _{2H3+} , II _{2H3P}	20	30/37, 37	... 38	38
PL	II _{2E3P} , II _{2E3B/P}	20	37, 30	... 40	40
LV	II _{2H3B/P}	20	30	... 42	42
LT	II _{2H3B/P}	20	30	... 44	44
LU	I _{2E}	20		... 46	46
HU	II _{2H3B/P}	25	30, 50	... 48	48
DE	II _{2ELL3B/P} , II _{2ELL3P}	20	50	... 50	50
NO	II _{2H3B/P}	20	30	... 52	52
IT	II _{2H3+}	20	30/37	... 54	54
PT	II _{2H3+} , II _{2H3P}	20	30/37, 37	... 56	56
RO	II _{2H3B/P}	20	30	... 58	58
ES	II _{2H3+} , II _{2H3P}	20	30/37, 37		
CH	II _{2H3B/P} , II _{2H3+} , II _{2H3P}	20	50, 30/37, 37		
SE	II _{2H3B/P}	20	30		
SK	II _{2H3B/P} , II _{2H3P}	20	30, 37, 50		
SI	II _{2H3B/P} , II _{2H3P}	20	30, 37		
TR	I _{2H} , I _{3P} , I _{3B/P}	20	37		
UA, RU, BA, MD	II _{2H3B/P}	20	30, 50		
RS, HR	II _{2H3B/P}	20	30, 50		

Flue system code: B₂₃, C₁₃, C₃₃, C₅₃, C₈₃*
 Flue system duct diameter: Models from ...12 to ...48 Ø150/Ø100 mm
 Models from ...50 Ø200/Ø150

Electric supply: AC 230 V 50 Hz

Remark: * Type C₈₃ only if 2 mbar natural draught is ensured in the duct.

The appliances were tested together with the flue evacuating system required by the manufacturer.

The models of the applied flue pipes: LIM-MONT ECO DIM DW; LIM-MONT ECO DIM DE.

Date of issue:

Budapest, 29.01.2014

Certification Body


Sandor Endre Szabo

TÜV Rheinland InterCert Kft. – Product Certification Body – H-1132 Budapest, Váci út 48/A-B – www.tuv.hu