

EU Type-Examination Certificate



according to Regulation (EU) 2016/426 Article 14, section 2.
on appliances burning gaseous fuels – Module B – production type

Certificate No.: MB 69262020 0001 **PIN:** 1008 CU 3305

Test Report No.: 28249549 001

Certificate Holder: Pakole Trade Kft.
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.

Manufacturer: Pakole Trade Kft.
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.

Product: Group: Heating and air conditioning appliances (3300)

Indirect gas-fired forced convection condensing air heaters for space heating (3321)

Identification: Models:
GTV-CON 27/19A, C, CL; GTV-CON 40/28A, C, CL;
GTV-CON 58/40A, C, CL.

See details in Annex I.

Tested according to: EN 1020:2009,
EN 1196:2011

Countries of destination: AT, BA, BG, CH, CZ, DE, DK, EE, ES, FI, GB, GR, HR, HU,
IE, IT, LT, LU, LV, MD, NO, PL, PT, RO, RS, RU, SE, SI,
SK, TR, UA

Valid until 11.06.2029

This EU type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Regulation. The Certificate holder is entitled to use this certificate in connection with the EU declaration of conformity in accordance with the Regulation. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

Date of issue:
Budapest, 11.06.2019



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
Notified under No. 1008 in EU

The CE marking may be used if all relevant and effective EC directives are complied with.

Annex I to certificate No. MB 69262020 0001

Page 1/1

PIN: 1008 CU 3305

Specifications of the appliances

Model	Nominal heat input [kW]	Appliance category	Gas supply pressure (mbar)	Countries of destination
GTV-CON 27/19A, C, CL	27	I _{2H}	20	AT, BA, BG, CH, CZ, DK, EE, ES, FI, GB, GR, HR, IE, IT, LT, LV, MD, NO, PT, RO, RS, RU, SE, SI, SK, TR, UA
GTV-CON 40/28A, C, CL	40	I _{2E}	20	LU, DE, PL
GTV-CON 58/40A, C, CL	58	I _{2H}	25	HU

Control: three point and modulation

Flue discharge types: B₂₂, C₁₂, C₃₂, C₅₂

Electrical supply: 230V, 50 Hz

The appliances were tested together with the flue system, defined by the manufacturer.

Applied flue system parts: LIM-MONT ECO DIM DW; LIM-MONT ECO DIM DE

Main built in components

Description of the component	Manufacturer	Model	Conformity document
MFC	SIT S.p.A.	Sigma 845S 0840064	PIN: 0063AS4831
Burner controller	SIT S.p.A.	DBC 579 0579405	PIN: CE-0085BS0088
Combined thermostat	Honeywell	L 4064 B2210B	
Safety temperature limiter	IMIT	LS MAN. 100C IM	
Flue gas pressure sensing device	Honeywell (YAMATAKE)	C6065F1183:2 (03287F, vízszintes membrán)	
	Unicontrol Inc	NS2-1322-00 / RED 20-27 kW	
	Unicontrol Inc	NS2-1322-00 / GREEN 33-40kW	
	Unicontrol Inc	NS2-1322-00 / BLUE 33-40kW	
Flue fan (27/19, 40/28)	OSX1338.2L250 (V12-C009)	Ma-Vib	
Flue fan (58/40)	VA3	AACO	
Burner	11010X	Becket Gas	

Date of issue:

Budapest, 11.06.2019



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu