

# EU Type-Examination Certificate



according to Regulation (EU) 2016/426 Article 14, section 2.  
on appliances burning gaseous fuels – Module B – production type

**Certificate No.:** MB 69261119 0002 **PIN:** 1008 CT 3271  
**Test Report No.:** 28247713 002  
**Certificate Holder:** Pakole Trade Kft.  
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.  
**Manufacturer:** Pakole Trade Kft.  
H - 8000 Székesfehérvár, Börgöndi út 8 - 10.  
**Product:** **Group:** Heating and air conditioning appliances (3300)  
Gas-fired overhead radiant tube heaters (3311)  
**Identification:** **Models:**  
VARIANT II, VARIANT II 70+  
See details in Annex I.  
**Tested according to:** EN 416-1:2009  
**Countries of destination:** AT, BE, BY, CY, CZ, DK, GB, EE, FI, FR, GR, NL, IE, PL,  
LV, LT, LU, HU, DE, NO, IT, PT, RO, ES, CH, SE, SK, SI,  
TR, UA, RU, BA, BG, MD, RS, HR  
**Valid until** 14.12.2028

This EU type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Regulation. The Certificate holder is entitled to use this certificate in connection with the EU declaration of conformity in accordance with the Regulation. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

**Date of issue:**  
Budapest, 10.09.2019



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu  
Notified under No. 1008 in EU

The CE marking may be used if all relevant and effective EC directives are complied with.

**Annex I to certificate No. MB 69261119 0002**

Page 1/2

**PIN: 1008 CT 3271**

Destination countries	Appliance categories
AT	II <sub>2H(20)3B/P(50)</sub>
BG	II <sub>2H(20)3B/P(30)</sub>
BY	II <sub>2H(20)3B/P(30, 50)</sub>
CY	I <sub>2H(20)</sub>
CZ	II <sub>2H(20)3P(37)</sub>
DK	II <sub>2H(20)3B/P(30)</sub>
GB	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37, 50)</sub>
EE	II <sub>2H(20)3B/P(30)</sub>
FI	II <sub>2H(20)3B/P(30)</sub>
GR	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
NL	I <sub>3B/P(30)</sub> , I <sub>3P(50)</sub>
IE	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
PL	II <sub>2E(20)3P(37)</sub> , II <sub>2E(20)3B/P(30)</sub>
LV	II <sub>2H(20)3B/P(30)</sub>
LT	II <sub>2H(20)3B/P(30)</sub>
LU	I <sub>2E(20)</sub>
HU	II <sub>2HS(25)3B/P(30)</sub>
DE	II <sub>2ELL(20)3B/P(50)</sub> , II <sub>2ELL(20)3P(50)</sub>
NO	II <sub>2H(20)3B/P(30)</sub>
IT	I <sub>2H(20)</sub>
PT	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
RO	II <sub>2H(20)3B/P(30)</sub>
ES	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
CH	II <sub>2H(20)3B/P(50)</sub> , I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
SE	II <sub>2H(20)3B/P(30)</sub>
SK	II <sub>2H(20)3B/P(30)</sub> , II <sub>2H(20)3P(37, 50)</sub>
SI	II <sub>2H(20)3B/P(30)</sub> , II <sub>2H(20)3P(37)</sub>
TR	I <sub>2H(20)</sub> , I <sub>3P(37)</sub> , I <sub>3B/P(20)</sub>
UA, RU, BA, MD	II <sub>2H(20)3B/P(30, 50)</sub>
RS, HR	II <sub>2H(20)3B/P(50)</sub>

Models: VARIANT II	Nominal hest input (kW)
... 12	12
... 14	14
... 16	16
... 18	18
... 20	20
... 22	22
... 24	24
... 26	26
... 28	28
... 30	30
... 32	32
... 34	34
... 36	36
... 38	38
... 40	40
... 42	42
... 44	44
... 46	46
... 48	48
... 50	50
... 52	52
... 54	54
... 56	56
... 58	58

Flue type: B<sub>23</sub>, B<sub>53</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>53</sub>, C<sub>83</sub>  
 Flue pipes diameter: Models from ...12 to ...48-ig Ø150/Ø100 mm  
 Models from ...50 Ø200/Ø150  
 Electrical supply: AC 230 V 50 Hz  
 Flue pipe brands: LIM-MONT ECO DIM DW, LIM-MONT ECO DIM DE.

**Date of issue:**  
Budapest, 10.09.2019

**Certification Body**  
  
 TÜVRheinland<sup>®</sup>  
 Notified Body 1008  
 1. Zoltán Spreitzer

**TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu**

**Annex I to certificate No. MB 69261119 0002**

Page 2/2

PIN: 1008 CT 3271

Destination countries	Appliance categories
AT	II <sub>2H(20)3B/P(50)</sub>
BG	II <sub>2H(20)3B/P(30)</sub>
BY	II <sub>2H(20)3B/P(30, 50)</sub>
CY	I <sub>2H(20)</sub>
CZ	II <sub>2H(20)3P(37)</sub>
DK	II <sub>2H(20)3B/P(30)</sub>
GB	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37, 50)</sub>
EE	II <sub>2H(20)3B/P(30)</sub>
FI	II <sub>2H(20)3B/P(30)</sub>
GR	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
NL	I <sub>3B/P(30)</sub> , I <sub>3P(50)</sub>
IE	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
PL	II <sub>2E(20)3P(37)</sub> , II <sub>2E(20)3B/P(30)</sub>
LV	II <sub>2H(20)3B/P(30)</sub>
LT	II <sub>2H(20)3B/P(30)</sub>
LU	I <sub>2E(20)</sub>
HU	II <sub>2HS(25)3B/P(30)</sub>
DE	II <sub>2ELL(20)3B/P(50)</sub> , II <sub>2ELL(20)3P(50)</sub>
NO	II <sub>2H(20)3B/P(30)</sub>
IT	I <sub>2H(20)</sub>
PT	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
RO	II <sub>2H(20)3B/P(30)</sub>
ES	I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
CH	II <sub>2H(20)3B/P(50)</sub> , I <sub>2H(20)</sub> , II <sub>2H(20)3P(37)</sub>
SE	II <sub>2H(20)3B/P(30)</sub>
SK	II <sub>2H(20)3B/P(30)</sub> , II <sub>2H(20)3P(37, 50)</sub>
SI	II <sub>2H(20)3B/P(30)</sub> , II <sub>2H(20)3P(37)</sub>
TR	I <sub>2H(20)</sub> , I <sub>3P(37)</sub> , I <sub>3B/P(20)</sub>
UA, RU, BA, MD	II <sub>2H(20)3B/P(30, 50)</sub>
RS, HR	II <sub>2H(20)3B/P(50)</sub>

Models: VARIANT II 70+	Nominal heat input (kW)
/12/L.. OR U..	12
/14/L.. OR U..	14
/16/L.. OR U..	16
/18/L.. OR U..	18
/20/L.. OR U..	20
/22/L.. OR U..	22
/24/L.. OR U..	24
/26/L.. OR U..	26
/28/L.. OR U..	28
/30/L.. OR U..	30
/32/L.. OR U..	32
/34/L.. OR U..	34
/36/L.. OR U..	36
/38/L.. OR U..	38
/40/L.. OR U..	40
/42/L.. OR U..	42
/44/L.. OR U..	44
/46/L.. OR U..	46
/48/L.. OR U..	48

 Flue type:  
 Flue pipes diameter:  
 Flue pipe brands:

 B<sub>23</sub>, B<sub>53</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>53</sub>, C<sub>83</sub>  
 Ø150/Ø100 mm  
 LIM-MONT ECO DIM DW, LIM-MONT ECO DIM DE

**Date of issue:**

Budapest, 10.09.2019


**TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu**